



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 04.08.2016

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **ZIMMER CANCER CENTER RENOVATION [TRC Plan Review #3]**



TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The proposed signs within the 100' island are located within the SDT of the drop off area for the Zimmer Cancer Center addition, (One Way Sign, Pedestrian Crossing Sign and Do Not Enter Sign). Ensure the location and height of these signs do not obscure the clear visual sight distance from 30" to 10' for this location.
2. Please ensure the proposed Crape Myrtles in the 100' island do not obscure the clear visual sight distance from 30" to 10'.
3. As previously stated, update the proposed landscaping plan to match current submission.
4. No Further Comments.